

## Update package description

Used to update HVAC series PLC. Need to use USB Cable or RS232 Cable.

List of supported models:

PR-22AD-PTDAI-RA

PR-23AD-PTDAI-RA

When the above-mentioned PLC uses **xLogicSoft-V3.4.5.6**, it is necessary to use this update package to update the firmware of the PLC, otherwise the program cannot be downloaded.